Phone:080-22945350 **Email:**cewwmwest@bwssb.gov.in

BANGALORE WATER SUPPLY AND SEWERAGE BOARD
Office of The Chief Engineer (Waste Water Management-West)
6th Floor, Cauvery Bhavan, KG Road, Bangalore - 560009

No.BWSSB/ CE(WWM-West)/ ACE(WWM-H&AV-W)/DCE(WWM-E&W)/ TA-2/ /2025-26
Date: 21/11/25 1566

ADDENDUM/CORRIGENDUM

Sub: Tender for the Work of comprehensive Operation and Maintenance of 20 MLD Used Water Treatment Plant (UWTP) at Horamavu for a period of 5 years.

Ref: IFT No: BWSSB/ CE(WWM-W)/ACE(WWM-H&AV-W)/DCE(WWM-E&W)/TA-2/1382/2025-26 Dt:27.10.2025..

~*~*~*~

With reference to the above subject, invitation for the tender was invited vide IFT mentioned in the above reference letter. This addendum/corrigendum indicates the replies to pre bid queries.

Chief Engineer(WWM-W)
BWSSB

Encl: Response to the pre bid Queries

Reply To Pre-Bid Queries For Work **of comprehensive Operation and Maintenance of 20 MLD Used Water Treatment Plant (UWTP) at Horamavu for a period of 5 years.**

IFT No: BWSSB/ CE(WWM-W)/ACE(WWM-H&AV-W)/DCE(WWM-E&W)/TA-2/1382/2025-26 Dt:27.10.2025.

Indent Number: BWSSB/2025-26/WT/WORK_INDENT2509

Sl.No	Tender Reference /Vol./ Clause No/	Page No	As per Tender Specification	Queries / Clarification Requested	Reply
1.	KPP Bid Document Final Horamavu Final	8	5. **EMD** shall be paid through OTC, NEFT, DEBIT CARD & CREDIT CARD through Karnataka Public Procurement Portal Only.	We request you to kindly consider the Earnest Money Deposit (EMD) in the form of a Bank Guarantee, in lieu of online payment. Please Confirm!	Tender condition Prevails
2	KPPP Bid Document Final Horamavu Final	10 & 11	**iii.** As a Prime Contractor, should have O&M Experience of 1 No of 16 MLD STP or 2 No of 8 MLD STP based on Sequencing Batch Reactor (SBR) Tertiary Treatment Unit/Additional Treatment Unit I,e., disc Filtration / Ultra Filtration/ Membrane Bio Reactor of minimum one year	The existing plant at Horamavu does not have a Tertiary Treatment Unit or Additional Treatment Facility (such as Disc Filtration or similar) so we requested to consider O&M Experience of 1 No 16 MLD STP or 2 No of 8 MLD STP based on Sequencing Batch Reactor (SBR) Only. Please Confirm!	Tender condition Prevails

3	KPPP Bid Document Final Horamavu Final	11 & 12	**3.6 Available tender capacity** :- Note: The statements showing the value of existing Commitments and ongoing works as well as the stipulated period of completion remaining for each of the works listed should be countersigned by the Employer in charge, not below the rank of an Executive Engineer or equivalent.	However, in our case, the projects are located in multiple sates and obtaining countersignatures from all concerned Executive Engineers within the short tender timeline is partially not feasible. We therefore request the authority to kindly clarify whether any of the following documents will be accepted in place of EE countersigned statements: CA-certified Work – in-Hand / ongoing Works Statement, OR Latest RA Bill certified and signed by the competent authority of the respective projects. We request confirmation on whether these alternative documents will be acceptable for bid submission. Please Confirm!	Tender condition Prevails
4	KPPP Bid Document Final Horamavu Final	24 & 25	BANKER'S CERTIFICATE This is to certify that M/s…….. is a reputed company with a good financial standing. If the contract for this work, namely	However, the tender document does not specify the required credit/OD amount that the Banker's Certificate should mention.	Tender condition Prevails

			.....(name of the work) is awarded to the above firm, we shall be able to provide overdraft/credit facilities to the extent of Rs..... to meet the working capital requirements for executing the above contract Sd/- Name of the Bank, Senior Bank Manager Address:	What is the minimum overdraft/credit facility amount that needs to be certified in the Banker's Certificate for this tender?"	
5	**Common Query** **3.Qualification of the Tender :** 3.2.a) i)		The tenderer as prime contractor should have satisfactorily completed at least one similar work such as Operation and Maintenance of Used Water Treatment Plant (UWTP) of value not less than **Rs.649.09 lakh** in the last five financial years.	The amount put to tender is Rs.1298.17 lakhs for 5 years of Operation and Maintenance contract. Hence, the value of cost per Annum is Rs.259.64 lakhs. We request to consider the per Annum cost of Rs.259.64 lakhs for meeting the pre – qualification for this tender. Kindly Consider.	Tender condition Prevails
6	**Common Query** **3.Qualification of the Tender :** 3.2.a) iii)		As a Prime Contractor, should have O&M Experience of 1 No of 16 MLD STP or 2 No of 8 MLD STP based on Sequencing Batch Reactor (SBR) Tertiary Treatment Unit / Additional Treatment Unit i,e., disc Filtration / Ultra Filtration / Membrane Bio Reactor of Minimum one year.	We request to consider O&M Experience of **Only STP** of 1 No of 16 MLD STP or 2 No of 8 MLD STP based on Sequencing Batch Reactor (SBR) Technology to this condition. Kindly Consider.	Tender condition Prevails

7	37. Payments 42. Liquidated damages		The Contractor shall be liable to pay liquidated damages for shortfall in progress.	Bidder request you to kindly confirm the maximum limit of Liquidated Damages as the Contract Data page does not clearly specify the cap in the uploaded documents.	The maximum amount of liquidated damages for the whole of the works is **ten** (10) percent of final contract price.
8	BRIEF DESCRIPTION OF THE PLANT		Treated Effluent Quality Requirements	The bidder requests you to please confirm whether the plant is currently complying the NGT standards or not.	Plant is designed to NGT norms. ~~with the parameters prescribed in the tender~~
9	Section 8		1.Plant Layout (Attached) 2.P and ID 3.HFD 4. Electrical Load List	Bidder request you to kindly provide the documents mentioned in the Section 8 on the tender document	Enclosed

Chief Engineer(WWM-W)
BWSSB